Series 10-SZ3000 / Plug-in Type



	Model Manifold		D-sub connector	Flat ribbon cable type 60P□			
			Type 60F	Type 60P	Type 60PG	Type 60PH	
			Plug-in type				
	1 (P: SUP), 3/5 (R: EXH)		Common SUP, EXH				
r	Valve stations (V	Vith pow	er terminal)	2 to 20 stations		2 to 16 stations	2 to 8 stations
	Applicable connector		D-sub connector Conforming to MIL-C-24308 JIS-X-5101	Flat ribbon cable connector Socket: 26 pin MIL type with strain relief Conforming to MIL-C-83503	Flat ribbon cable connector Socket: 20 pin MIL type with strain relief Conforming to MIL-C-83503	Flat ribbon cable connector Socket: 10 pin MIL type with strain relief Conforming to MIL-C-83503	
k	Internal wiring		+COM, -COM				
	4(A), 2(B) port	4(A), 2(B) port Location		Valve			
	Porting specifications Direction		Lateral, Upward, Downward				
	Port size Metric Inch		c	1(P), 3/5(R) port: ø8 4(A), 2(B) port: M5, ø4, ø6		5, ø4, ø6	
			1(P), 3/5(R) port: ø5/16"		4(A), 2(B) port: ø5/32", ø1/4"		

Series 10-SZ3000 / Non Plug-in Type



Model			Type 10	D-SS5Z3-60
Manifold			Non plug-in type	
1 (P: SUP), 3/5 (R: EXH)			Common SUP, EXH	
Valve stations			2 to 20 stations	
4(A), 2(B) port Location		Location	1	/alve
Porting specifi	cations	Direction	Lateral, Upv	vard, Downward
Port size	Metric	;	1(P), 3/5(R) port: ø8	4(A), 2(B) port: M5, ø4, ø6
Port Size	Inch		1(P), 3/5(R) port: ø5/16"	4(A), 2(B) port: ø5/32", ø1/4"

Series 10-SZ3000 / Serial Transmission Type



Protocol type	CE-compliant
NKE Corp.: Fieldbus System	_
NKE Corp.: Fieldbus H System	_
Panasonic Industrial Devices SUNX Co., Ltd.: S-LINK (16 outputs)	_
Panasonic Industrial Devices SUNX Co., Ltd.: S-LINK (8 outputs)	_
DeviceNet™	0
OMRON Corp.: CompoBus/S (16 outputs)	0
OMRON Corp.: CompoBus/S (8 outputs)	0
CC-Link	0

Cylinders

Air


Series 10-SZ3000 5 Port Solenoid Valve Plug-in Type




How to Order

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

Plug-in manifold with power supply terminal



Connector type



SUP/EXH block mounting position

U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 20 stations)
M * Special specifications	

 For special specifications, indicate separately with the manifold specification sheet.

Note) A total of up to 3 SUP/EXH blocks can be mounted. Please contact SMC if 4 or

Pilot type

	Nil	Internal pilot
	R	External pilot

more will be mounted.

Nil	Internal pilot
R	External pilot

Option

When a longer DIN rail is desired than the specified stations, specify the station number to be required.

CE-compliant

♦Power supply terminal

Symbol	Specifications
P	24 VDC, Positive common
P12	12 VDC, Positive common
N	24 VDC, Negative common
N12	12 VDC, Negative common

SUP/EXH block fitting type

Nil	Straight
L	Elbow (Upward)
В	Elbow (Downward)

Valve stations


F: D-sub connector

Symbol	Stations	Note	
02	2 stations		
:	:	Double wiring Note 1)	
10	10 stations		
02	2 stations		
-	:	Specified layout Note 2)	
20	20 stations	(Up to 21 solenoids possible)	

P: Flat ribbon cable connector (26 pins)

i i i iat nebeni easie connector (Ec pine,				
Symbol	Stations	Note		
02	2 stations			
-	:	Double wiring		
11	11 stations			
02	2 stations			
:	:	Specified layout (Up to 22 solenoids possible)		
20	20 stations	(Op to 22 octoriolds possible)		

Connector mounting position Symbol Mounting position



PG: Flat ribbon cable connector (20 pins)

1	ru.	ι ιαι πυυσι	reable confidential (20 pin	
	Symbol	Stations	Note	
	02	2 stations		
	:	:	Double wiring	
	08	8 stations		
	02	2 stations		
	:	:	Specified layout (Up to 16 solenoids possible	
	16	16 stations	(op to 10 colonolds possible	
	Note 1) Double wiring: Single, double, 3 position			

PH: Flat ribbon cable connector (10 pins)

		cable collineater (10 bille	
Symbol	Stations	Note	
02	2 stations		
:	:	Double wiring	
04	4 stations		
02	2 stations		
	:	Specified layout (Up to 8 solenoids possible)	
08	8 stations	(Op to a solations possible	
08	8 stations	(Op to a solellolds possible	

n and 4 position solenoid valves can be used at all of the manifold stations.


Note 2) Specified layout: Indicate wiring specifications on the manifold specification sheet. (Note that double, 3 position and 4 position valves cannot be used where single solenoid wiring has been specified.)


Pressure Switches/ Pressure Sensors



An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

• Plug-in manifold without power supply terminal





• How to order solenoid valve For plug-in (Common for both with and without power supply terminals)

How to Order

1(P) 3(EB)


How to Order Valve Manifold Assembly

Ordering example (10-SZ3000, positive common with power supply terminals)









Stations are counted from the D side as the 1st one.

Add the valve part number under the manifold part number.

For complex arrangements, specify them on the manifold specification sheet.

Manifold Specifications

Model			D-sub connector	Flat	ribbon cable type 6	60P□		
Model			Type 60F	Type 60P	Type 60PG	Type 60PH		
Manifold				Plug-in type				
1 (P: SUP), 3/5 (R: EXH)				Common	SUP, EXH			
Valve stations (With power terminal)			2 to 20	stations	2 to 16 stations	2 to 8 stations		
Applicable connector			D-sub connector Conforming to MIL-C-24308 JIS-X-5101	Socket: 26 pin MIL type with strain relief	Flat ribbon cable connector Socket: 20 pin MIL type with strain relief Conforming to MIL-C-83503	Socket: 10 pin MIL type with strain relief		
Internal wir	ing		+COM, -COM					
4(A), 2(B) port		Location	Valve					
Porting specific	cations	Direction	Lateral, Upward, Downward					
Port size	Metr	ic	1(P), 3/5(F	l) port: ø8	4(A), 2(B) port: M5, ø4, ø6			
Inch		1(P), 3/5(F	l) port: ø5/16"	4(A), 2(B) port: ø5/32", ø1/4"				
Weight W (g) Note 2) (n1: Stations n2: Number of SUP/EXH blocks) m: Weight of DIN rail			W = 3.2n1 + 53	in2 + m + 126.5				

Note 1) In cases such as those where many valves are operated simultaneously, use type B (double side SUP/EXH), applying pressure to the 1(P) ports on both sides and exhausting from the 3(R) ports on both sides.

Note 2) The weight W is the value for the D-sub connector manifold with power supply terminals only. To obtain the weight with solenoid valves attached, add the solenoid valve weights given on page 382 for the appropriate number of stations. For DIN rail weight, refer to page 384.

Flow Rate Characteristics

Port siz	ze	Flow rate characteristics							
1, 5, 3	4, 2	1 -	→ 2/4 (P → A	/B)	$4/2 \rightarrow (A/B \rightarrow R)$				
(P, EA, EB)	(A, B)	C [dm3/(s-bar)]	b	Cv	C [dm3/(s-bar)]	b	Cv		
	C4	0.58 [0.49]	0.26 [0.36]	0.14 [0.13]	0.76 [0.65]	0.15 [0.20]	0.18 [0.15]		
C8	C6 0.73 [0.64]		0.24 [0.27]	0.18 [0.16]	0.77 [0.74]	0.19 [0.16]	0.19 [0.19]		
	M5	0.60 [0.57]	0.38 [0.35]	0.17 [0.15]	0.67 [0.58]	0.16 [0.39]	0.16 [0.16]		

Note) \cdot The values are for individually operated 2 position type manifold bases with 5 stations.

Values inside [] are for 4 position dual 3 port valves.

Series			10-SZ3000		
Fluid			Air		
Internal pilot	2 position	single	0.15 to 0.7		
operating	2 position	double	0.1 to 0.7		
pressure range	3 position		0.2 to 0.7		
(MPa)	4 position	dual 3 port valve	0.15 to 0.7		
External pilot Operating		pressure range	-100 kPa to 0.7		
operating	Pilot	2 position single	0.25 to 0.7		
	pressure	2 position double	0.25 to 0.7		
	range	3 position	0.25 to 0.7		
Ambient and flu	id temperatu	ıre (°C)	-10 to 50 (No freezing. Refer to page 680.)		
Max. operating frequency (Hz)		single, double dual 3 port valve	10		
ricquericy (FIZ)	3 position		3		
Manual override	(Manual op	eration)	Non-locking push type, Push-turn locking slotted type		
Pilot type			Main/Pilot valve common exhaust		
Lubrication			Not required		
Mounting orient	ation		Unrestricted		
Impact/Vibration	n resistance	(m/s²) Note)	150/30		
Enclosure			Dust proof		
Note) Impact resistan	ce: No malfunc	tion occurred when it w	vas tested with a drop tester in the axial direction and at right angles to		

No malfunction occurred when it was tested with a drop tester in the axial direction and at right angles to the main valve and armature in both energized and de-energized states once for each condition. (Default

the main valve and animative modern scales and settings)
Vibration resistance: No malfunction occurred in a one-sweep test between 45 and 2000 Hz. Test was performed in both energized and de-energized states in the axial direction and at right angles to the main valve and armature. (Default settings)

Solenoid Specifications

Electrical entry	L type (For plug-in), M type plug connector (M)
Coil rated voltage (V) Note)	24, 12 VDC
Allowable voltage fluctuation	±10% of rated voltage
Power consumption (W)	0.6 (With light: 0.65)
Surge voltage suppressor	Diode
Indicator light	LED

Response Time

Note) Based on dynamic performance test, JIS B 8375-1981. (Coil temperature: 20°C, at rated voltage)

	Response time (ms) (at the pressure of 0.5 MPa)					
Actuation type	Without surge voltage suppressor	With surge voltage suppresser				
	Without surge voltage suppressor	S, Z type				
2 position single	12 or less	15 or less				
2 position double	10 or less	13 or less				
3 position	15 or less	20 or less				
4 position dual 3 port valve	30 or less	35 or less				

Weight

Port aizo							
Valve model	Actu	ation type	Port size	Weight (g)			
valve model	71010	anon typo	4(A), 2(B)	vvoigin (g)			
	2 position	Single		78			
	2 position	Double		84			
10-SZ3□60-□-C4 N3		Closed center	C4 N3				
10-323_60N3	3 position	Exhaust center	(ø4, ø5/32" One-touch fitting)	88			
		Pressure center	(One-touch litting)				
	4 position	Dual 3 port valve		84			
	2 position	Single		74			
10-SZ3□60-□- <mark>C</mark> 6 N7	2 position	Double	0.0	81			
	3 position	Closed center	C6 N7				
		Exhaust center	ø6, ø1/4" One-touch fitting	85			
		Pressure center	(One-touch litting)				
	4 position	Dual 3 port valve		81			
	0 141	Single		69			
	2 position	Double		75			
10-SZ3□60-□-M5		Closed center	M500				
10-323_00IVI3	3 position	Exhaust center	M5 x 0.8	79			
		Pressure center	1				
	4 position	Dual 3 port valve		75			

Manifold Option

■SUP block disk

By installing a SUP block disk in the pressure supply passage of a manifold valve, it is possible to supply two or more different high and low pressures to one manifold. (Use in combination with a pilot port block disk.)



Series	Part no.
10-SZ3000	SZ3000-114-4A

■EXH block disk

By installing an EXH block disk in the exhaust passage of a manifold valve, it is possible to divide the valve's exhaust so that it does not affect another valve. (Two block disks are needed to divide both exhausts.)



Series	Part no.
10-SZ3000	SZ3000-114-4A

■Pilot port block disk


By installing a pilot port block disk in the pilot passage of a manifold valve, it can be function as an internal pilot/external pilot mixed manifold. (Use in combination with a SUP or EXH block disk.)



Series	Part no.
10-SZ3000	SZ3000-114-2A


■Blanking block assembly SZ3000-55-1A

These are mounted when later addition of valves is planned, etc.



■Plug (White)

These are inserted in unused cylinder ports or SUP/EXH ports. Purchase orders are available in units of 10 pieces.




Dimensions

Applicable fitting size ød	Model	А	L	D
4	10-KQP-04	16	32	ø6
6	10-KQP-06	18	35	ø8
8	10-KQP-08	20.5	39	ø10
5/32"	10-KQP-03	16	32	ø6
1/4"	10-KQP-07	18	35	ø8.5
5/16"	10-KQP-09	20.5	39	ø10

Air


Marinola Option

■DIN rail dimensions / Weight



Refer to the L dimension tables

* Enter a number from the DIN rail dimension table below.




No.	0	1	2	3	4	5	6	7	8	9
L dimension	98	110.5	123	135.5	148	160.5	173	185.5	198	210.5
Weight (g)	17.6	19.9	22.1	24.4	26.6	28.9	31.1	33.4	35.6	37.9

No.	10	11	12	13	14	15	16	17	18	19
L dimension	223	235.5	248	260.5	273	285.5	298	310.5	323	335.5
Weight (g)	40.1	42.4	44.6	46.9	49.1	51.4	53.6	55.9	58.1	60.4

■Flat ribbon cable type / Cable assembly

AXT100-FC□-to



Flat Ribbon Cable Assembly

Cable length (L)	10 pins	20 pins	26 pins
1.5 m	AXT100-FC10-1	AXT100-FC20-1	AXT100-FC26-1
3 m	AXT100-FC10-2	AXT100-FC20-2	AXT100-FC26-2
5 m	AXT100-FC10-3	AXT100-FC20-3	AXT100-FC26-3
Connector width (W)	17.2	30	37.5


* For other commercial connectors, use a type with strain relief conforming to MIL-C-83503.

Example of connector manufacturers

- HIROSE ELECTRIC CO., LTD.
- Japan Aviation Electronics Industry, Limited
- 3M Japan Limited
- J.S.T. Mfg. Co., Ltd.
- Fujitsu Limited

■D-sub connector (25 pins) / Cable assembly

AXT100-DS25- 030



D-sub Connector Cable Assembly Terminal No.

Lead wire color Black Brown Red Orange Yellow Pink Blue Purple Gray White White Yellow Orange	None None None None None None None None
Brown Red Orange Yellow Pink Blue Purple Gray White White Yellow	None None None None None None None None
Red Orange Yellow Pink Blue Purple Gray White White Yellow	None None None None None None None Black Black Red Red
Orange Yellow Pink Blue Purple Gray White White Yellow	None None None None None None Black Black Red Red
Yellow Pink Blue Purple Gray White White Yellow	None None None White Black Black Red Red
Pink Blue Purple Gray White White Yellow	None None White Black Black Red Red
Blue Purple Gray White White Yellow	None White Black Black Red Red
Purple Gray White White Yellow	White Black Black Red
Gray White White Yellow	Black Black Red Red
White White Yellow	Black Red Red
White Yellow	Red Red
Yellow	Red
Orange	
	Red
Yellow	Black
Pink	Black
Blue	White
Purple	None
Gray	None
Orange	Black
Red	White
Brown	White
Pink	Red
FIIIK	
Gray	Red
	Red White

D-sub Connector Cable Assembly

Cable length (L)	Assembly part no.	Note
1.5 m	AXT100-DS25-015	
3 m	AXT100-DS25-030	Cable 25 cores x 24AWG
5 m	AXT100-DS25-050	X Z-JAWG

For other commercial connectors, use a 25 pin type with female connector conforming to MIL-C-24308.

Example of connector manufacturers

- HIROSE ELECTRIC CO., LTD.
- Japan Aviation Electronics Industry, Limited
- J.S.T. Mfg. Co., Ltd.
- Fujitsu Limited

Electric Characteristics

Item	Characteristics
Conductor resistance Ω/km, 20°C	65 or less
Withstand limit VAC, 1 minute	1000
Insulation resistance MΩkm, 20°C	5 or less


Note) The minimum bending radius of the D-sub connector cable is 20 mm.



Manifold Electrical Wiring

Type 60F D-sub Connector Type (25 pins)


Without Power Supply Terminal



- The common polarity should be the same as the common specifications of the valve to be used.
- common specifications of the valve to be used.

 The maximum number of stations that can be accommodated is 20 manifold stations, with up to 24 solenoids.


With Power Supply Terminal



- The circuits above are for the double wiring specification with up to 10 or 12 stations. Connect to SOL.A for a single solenoid. Moreover, when wiring instructions are given on the manifold specification sheet, the "A" signal for single and the "A, B" signals for double should be wired in order 1, 14, 2, 15.....etc., without skipping or leaving any connectors remaining.
- . Stations are counted from the D side as the 1st one.


Type 60P Flat Ribbon Cable Type (26 pins) -

Without Power Supply Terminal




- The common polarity should be the same as the common specifications of the valve to be used.
- The maximum number of stations that can be accommodated is 20 manifold stations, with up to 25 solenoids.

With Power Supply Terminal




- The circuits above are for the double wiring specification with up to 11 or 12 stations. Connect to SOL.A for a single solenoid. Moreover, when wiring instructions are given on the manifold specification sheet, the "A" signal for single and the "A, B" signals for double should be wired in order 1, 2, 3, 4.....etc., without skipping or leaving any connectors remaining.
- . Stations are counted from the D side as the 1st one.
- Since terminal numbers are not indicated on the flat cable, use the triangle mark as a reference for wiring.

Without Power Supply Terminal



- . The common polarity should be the same as the common specifications of the valve to be used.
- . The maximum number of stations that can be accommodated is 19 manifold stations, with up to 19 solenoids.


With Power Supply Terminal



- The circuits above are for the double wiring specification with up to 8 or 9 stations. Connect to SOL.A for a single solenoid. Moreover, when wiring instructions are given on the manifold specification sheet, the "A" signal for single and the "A, B" signals for double should be wired in order 1, 2, 3, 4.....etc., without skipping or leaving any connectors remaining.
- . Stations are counted from the D side as the 1st one.
- · Since terminal numbers are not indicated on the flat cable, use the triangle mark as a reference for wiring.


Type 60PH Flat Ribbon Cable Type (10 pins) -

Without Power Supply Terminal



- . The common polarity should be the same as the common specifications of the valve to be used.
- The maximum number of stations that can be accommodated is 9 manifold stations, with up to 9 solenoids

With Power Supply Terminal



- The circuits above are for the double wiring specification with up to 4 stations. Connect to SOL.A for a single solenoid. Moreover, when wiring instructions are given on the manifold specification sheet, the "A" signal for single and the "A, B" signals for double should be wired in order 1, 2, 3, 4.....etc., without skipping or leaving any connectors remaining
- Stations are counted from the D side as the 1st one
- Since terminal numbers are not indicated on the flat cable, use the triangle mark as a reference for wiring.

Cylinders Air

Actuators Rotary 1

Preparation

Grippers

Air Preparat Equipment

Modular Control Pressure Contr Equipment

& Tubing Fittings

Flow Control Equipment Control


Switches/ e Sensors Pressure Pressure




Wiring of Plug-in Type Manifold with Power Supply Terminal (Example)

• Since the power supply to drive valves with power supply terminals can be supplied from either the control side or the manifold side, these wiring examples should be used for reference when wiring is performed.

1. Wiring example when using manifold power supply terminal




Wiring example when not using manifold power supply terminal (Power is supplied to the control side or along the wiring, etc.)





∧ Caution

 Signal wire, COM position, etc. of PLC are different from each manufacturer. When connecting with PLC, read the specifications carefully and understand the electrical circuit. Poor wiring could cause damage to PLC, power source, etc. as well as manifold and valve.

10-SS5Z3-60FD 2- Stations U-□








Inter	nal Pil	ot Mar	nifold	L Din	nensio	n: Stations			
$\overline{\mathbb{N}}$	2	3	4	5	6	7	8	9	10
L1	110.5	123	135.5	148	148	160.5	173	185.5	198
L2	100	112.5	125	137.5	137.5	150	162.5	175	187.5
L3	81	91.5	102	112.5	123	133.5	144	154.5	165
L4	15	16	17	18	12.5	13.5	14.5	15.5	16.5


Exte	External Pilot Manifold L Dimension n: Statio											
<u></u>	2	3	4	5	6	7	8	9	10			
L1	123	135.5	148	148	160.5	173	185.5	198	210.5			
L2	112.5	125	137.5	137.5	150	162.5	175	187.5	200			
L3	91.5	102	112.5	123	133.5	144	154.5	165	175.5			
L4	16	17	18	12.5	13.5	14.5	15.5	16.5	17.5			

10-SS5Z3-60FD2- Stations B-



Exte	rnal Pil	ot Man	ifold	L Dim	ensio	n												n:	Stations
$\overline{}$	n 2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	248	248	260.5	273	285.5	298	310.5	310.5	323
L2	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	237.5	237.5	250	262.5	275	287.5	300	300	312.5
L3	107.5	118	128.5	139	149.5	160	170.5	181	191.5	202	212.5	223	233.5	244	254.5	265	275.5	286	296.5
L4	14	15	16	17	12	13	14	15	16	17	18	12.5	13.5	14.5	15.5	16.5	17.5	12.5	13.5

10-SS5Z3-60PD 2 - Stations U- (26 pins)



Inter	nal Pil	ot Maı	nifold	L Din	nensio	n		n:	Stations
<u></u>	2	3	4	5	6	7	8	9	10
11	110.5	123	135.5	148	148	160.5	173	185.5	108

		2	3	4	5	6	7	8	9	10
	L1	110.5	123	135.5	148	148	160.5	173	185.5	198
	L2	100	112.5	125	137.5	137.5	150	162.5	175	187.5
	L3	81	91.5	102	112.5	123	133.5	144	154.5	165
	L4	15	16	17	18	12.5	13.5	14.5	15.5	16.5
-										

Exte	n:	Station							
	2	3	4	5	6	7	8	9	10
L1	123	135.5	148	148	160.5	173	185.5	198	210.5
	440.5	405	407.5	407.5	450	400.5	475	407.5	000

Note 2) For manifold dimensions with elbow fitting, refer to page 392.

E	External Pilot Manifold L Dimension n: Station												
\overline{L}	/5	2	3	4	5	6	7	8	9	10			
	1	123	135.5	148	148	160.5	173	185.5	198	210.5			
L	_2	112.5	125	137.5	137.5	150	162.5	175	187.5	200			
L	_3	91.5	102	112.5	123	133.5	144	154.5	165	175.5			
L	_4	16	17	18	12.5	13.5	14.5	15.5	16.5	17.5			

10-SS5Z3-60PD 2 - Stations B- (26 pins) [4(A), 2(B) port] [With External Pilot Specifications] One-touch fitting [1(P), 3(R) port] 13.3 $\dot{P} = 10.5$ Applicable tubing O.D.: ø8, ø5/16" 34 One-touch fitting (X. PE port) One-touch fitting Applicable tubing O.D.: ø6, ø1/4" [4(A), 2(B) port] Applicable tubing O.D.: ø4, ø5/32 Applicable connector: ø6, ø1/4 26 pin MIL type with strain relief (Conforming to MIL-C-83503) 6.6 Switch for locking a connector (X) 36.3 Triangle mark 58.2 ◈ Triangle mark position Manual override DIN rail (When equipped with switch) 3.5 Press and turn for 22 the locking type. DIN rail holding screw (The voltage indication marking is for 24 VDC.) 4(A) port side: Orange 2(B) port side: Green 12 Applicable connector: Applicable connector: 5 20 pin MIL type with strain relief 10 pin MIL type with strain relief (Rail mounting hole pitch 12.5) (Conforming to MIL-C-83503) (Conforming to MIL-C-83503) 11 Power supply terminal (M3 terminal screw) (Station n) (Station 1) Light/surge voltage suppresso 18.9 62. 13.5 34.2 Triangle mark position Triangle mark position 60PG (20 pins) 60PH (10 pins) Switch Note 1) Types 60PG and 60PH differ only in their connectors, and the L1 through (When equipped with switch) L4 dimensions are the same as type 60P. Note 2) For manifold dimensions with elbow fitting, refer to page 392. Internal Pilot Manifold L Dimension n: Stations 2 3 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 11 123 135.5 148 160.5 173 173 185.5 198 210.5 223 235.5 248 248 260.5 273 285.5 298 310.5 310.5 L2 112.5 137.5 150 162.5 287.5 300 125 162.5 175 187.5 200 212.5 225 237.5 237.5 250 262.5 275 300 L3 97 107.5 118 128.5 139 149.5 160 170.5 181 191.5 244 254.5 286 202 212.5 223 233.5 265 275.5 14 15 17.5 13 14 16 17 12 13 14 15 17 12.5 13.5 145 15.5 16.5 12.5 16 18 **External Pilot Manifold** L Dimension n: Stations 2 3 4 5 8 9 10 11 12 13 14 15 16 17 18 19 20

L1 135.5

L2 125

L3

L4

107.5 118

148

137.5 150

15

160.5 173 173

128.5 139

162.5 | 162.5 | 175

149.5 160

191.5 202

210.5 223 235.5 248 248

185.5

198

187.5 200 212.5 225

170.5 181

14

17

260.5 273

233.5

12.5

262.5 275

14.5

244

237.5 237.5 250

212.5 223

285.5 298

254.5 265

310.5 310.5 323

275.5 286

312.5

296.5

287.5 300 300

16.5

rectional trol Valves


Air Cylinders


Rotary Actuators


Dimensions with Elbow Fitting: 10-SZ3000 for Plug-in, D-sub Connector


10-SS5Z3-60FD₂ - Stations U_B -

(The fitting dimension of the flat ribbon cable and non plug-in types is the same.)










Series 10-SZ3000 5 Port Solenoid Valve Non Plug-in Type



How to Order


An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

Non plug-in manifold



How to Order Valve Manifold Assembly


Ordering example (10-SZ3000, Non plug-in)





Stations are counted from the D side as the 1st one Add the valve part number under the manifold part number. For complex arrangements, specify them on the manifold specification sheet.

Air



How to Order

Cassette Type Manifold 10-SZ3000





Manifold Specifications

Model			Type 1	0-SS5Z3-60		
Manifold			Non p	lug-in type		
1 (P: SUP),	3/5 (R: EXH)		Common SUP, EXH			
Valve statio	ns		2 to 20 stations			
	4(A), 2(B) port Location		,	Valve		
Porting spe	cifications	Direction	Lateral, Upward, Downward			
Port size	Met	ric	1(P), 3/5(R) port: ø8	4(A), 2(B) port: M5, ø4, ø6		
FUIT SIZE	Inch	1	1(P), 3/5(R) port: ø5/16"	4(A), 2(B) port: ø5/32", ø1/4"		
Weight W (g) Note 2) (n: Number of SUP/EXH blocks m: Weight of DIN rail		W = 34r	n + m + 89			


Flow Rate Characteristics


Port siz	ze .		Flow rate characteristics										
1, 5, 3	4, 2	1 -	→ 2/4 (P → A	/B)	$4/2 \rightarrow 3 \text{ (A/B} \rightarrow \text{R)}$								
(P, EA, EB)	P, EA, EB) (A, B) C [dm ³ /(s		b	Cv	C [dm3/(s-bar)]	b	Cv						
	C4	0.58 [0.49]	0.26 [0.36]	0.14 [0.13]	0.76 [0.65]	0.15 [0.20]	0.18 [0.15]						
C8	C6	0.73 [0.64]	0.24 [0.27]	0.18 [0.16]	0.77 [0.74]	0.19 [0.16]	0.19 [0.19]						
	M5	0.60 [0.57]	0.38 [0.35]	0.17 [0.15]	0.67 [0.58]	0.16 [0.39]	0.16 [0.16]						


Note) - The values are for individually operated 2 position type manifold bases with 5 stations. · Values inside [] are for 4 position dual 3 port valves.

Note 1) In cases such as those where many valves are operated simultaneously, use type B (double side SUP/EXH), applying pressure to the 1(P) ports on both sides and exhausting from the 3(R) ports on both sides. Note 2) The weight W is the value for the manifold only. To obtain the weight with schenoid valves attached, add the solenoid valve weights given on page 382 for the appropriate number of stations. For DIN rail weight, refer to page 384.

10-SS5Z3-60- Stations U







(Station n).....(Station 1)

Note) For manifold dimensions with elbow fitting, refer to page 392.

Inter	nal Pil	ot Mar	nifold	L Din	nensio		n: Stations			
7	2	3	4	5	6	7	8	9	10	
L1	98	110.5	123	135.5	135.5	148	160.5	173	185.5	
L2	87.5	100	112.5	125	125	137.5	150	162.5	175	
L3	70	80.5	91	101.5	112	122.5	133	143.5	154	
L4	14	15	16	17	12	13	14	15	16	

Exte	External Pilot Manifold L Dimension												
L n	2	9	10										
L1	110.5	123	135.5	135.5	148	160.5	173	185.5	198				
L2	100	112.5	125	125	137.5	150	162.5	175	187.5				
L3	80.5	91	101.5	112	122.5	133	143.5	154	164.5				
L4	15	16	17	12	13	14	15	16	17				

10-SS5Z3-60-Stations D

[With External Pilot Specifications] One-touch fitting [1(P), 3(R) port] 13.3 (Pitch) Applicable tubing O.D.: ø8, ø5/16" 13.3 16.2 One-touch fitting One-touch fitting (X, PE port) [4(A), 2(B) port] Applicable tubing O.D.: ø6, ø1/4" Applicable tubing O.D.: ø4, ø5/32' ø6, ø1/4" U side D side 3.1 * 36 32 28.8 70.7 (*)

DIN rail holding screw

5


(Station n).....(Station 1)

Manual override

4(A) port side: Orange 2(B) port side: Green

(Press and turn for the locking type.)

(Rail mounting hole pitch 12.5)



Note) For manifold dimensions with elbow fitting, refer to page 392.

Approx. 300 Lead wire length

18.7


5 6	1			
, ,	/	8	9	10
5.5 135.5	148	160.5	173	185.5
5 125	137.5	150	162.5	175
1.5 112	122.5	133	143.5	154
7 12	13	14	15	16
	5.5 135.5 5 125 1.5 112	5.5 135.5 148 5 125 137.5 1.5 112 122.5	5.5 135.5 148 160.5 5 125 137.5 150 1.5 112 122.5 133	5.5 135.5 148 160.5 173 5 125 137.5 150 162.5 1.5 112 122.5 133 143.5

Exte	External Pilot Manifold L Dimension											
L	2	3	4	5	6	7	8	9	10			
L1	110.5	123	135.5	135.5	148	160.5	173	185.5	198			
L2	100	112.5	125	125	137.5	150	162.5	175	187.5			
L3	80.5	91	101.5	112	122.5	133	143.5	154	164.5			
L4	15	16	17	12	13	14	15	16	17			

113.7


DIN rail


10-SS5Z3-60-Stations B




25


[With External Pilot Specifications]





(Station n).....(Station 1)





Note) For manifold dimensions with elbow fitting, refer to page 392.

Interna	Internal Pilot Manifold L Dimension n: Stations																		
L_n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	110.5	123	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5	298	310.5
L2	100	112.5	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	225	237.5	250	262.5	275	287.5	300
L3	86	96.5	107	117.5	128	138.5	149	159.5	170	180.5	191	201.5	212	222.5	233	243.5	254	264.5	275
L4	12	13	14	15	16	17	12	13	14	15	16	17	12	13	14	15	16	17	18

External Pilot Manifold L Dimens	ion
----------------------------------	-----

Extern	External Pilot Manifold L Dimension n: Stations																		
_ n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	123	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	235.5	248	260.5	273	285.5	298	310.5	310.5
L2	112.5	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	225	237.5	250	262.5	275	287.5	300	300
L3	96.5	107	117.5	128	138.5	149	159.5	170	180.5	191	201.5	212	222.5	233	243.5	254	264.5	275	285.5
L4	13.5	14.5	15.5	16.5	17.5	12	13	14	15	16	17	12	13	14	15	16	17	18	12.5


Type 60S Series 10-SZ3000 EX140 Integrated-type (For Output) Serial Transmission System



Note) Refer to the SI unit part no. for the SI unit comparable with CE

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.

How to Order Manifold



SI unit part no

Si u	ilit part 110.		
Symbol	Protocol type	SI unit part no.	CE-compliant
Н	NKE Corp.: Fieldbus H System	EX140-SUH1	_
Q	DeviceNet™	EX140-SDN1	0
R1	OMRON Corp.: CompoBus/S (16 outputs)	EX140-SCS1	0
R2	OMRON Corp.: CompoBus/S (8 outputs)	EX140-SCS2	0
٧	CC-Link	EX140-SMJ1	0


U	U side (2 to 10 stations)
D	D side (2 to 10 stations)
В	Both sides (2 to 16 stations)
M*	Special specifications

For special specifications, indicate separately with the manifold specification sheet.

Note) A total of up to 3 SUP/EXH blocks can be mounted. Please contact SMC if 4 or more will be mounted.

How to Order Valve Manifold Assembly


Ordering example (CompoBus/S compatible SI unit)



10-SS5Z3-60SR1D-05U (-Q)------1 set (Manifold part no.) * 10-SZ3160-5LOZ-C6 (-Q)2 sets (Single solenoid part no.) * 10-SZ3260-5LOZ-C6 (-Q) ·······3 sets (Double solenoid part no.) The asterisk denotes the symbol for assembly. Prefix it to the part no. of the solenoid valve, etc.

Stations are counted from the D side as the 1st one. Add the valve part number under the manifold part number For complex arrangements, specify them on the manifold specification sheet.


Air



Dimensions: 10-SZ3000 for EX140 Integrated-type (For Output) Serial Transmission System

10-SS5Z3-60S□D- Stations U

[With External Pilot Specifications]



Inte	Internal Pilot Manifold L Dimension n: Stations													
<u></u>	2	3	4	5	6	7	8	9	10					
L1	135.5	148	160.5	173	185.5	185.5	198	210.5	223					
L2	125	137.5	150	162.5	175	175	187.5	200	212.5					
L3	108	118.5	129	139.5	150	160.5	171	181.5	192					

Ex	cte	n: Stations								
$\overline{}$	<u>_</u>	2	3	4	5	6	7	8	9	10
L	1	148	160.5	173	185.5	185.5	198	210.5	223	235.5
L	2	137.5	150	162.5	175	175	187.5	200	212.5	225
L	3	118.5	129	139.5	150	160.5	171	181.5	192	202.5
L	4	15	16	17	18	12.5	13.5	14.5	15.5	16.5

L4 14 15


16 17 18

12.5 13.5 14.5 15.5

Dimensions: 10-SZ3000 for EX140 Integrated-type (For Output) Serial Transmission System

10-SS5Z3-60S□D-Stations B

[With External Pilot Specifications]



Inte	Internal Pilot Manifold L Dimension n: Stations												
<u></u>	2	3	4	5	6	7	8	9					
L1	148	160.5	173	185.5	198	210.5	210.5	223					
L2	137.5	150	162.5	175	187.5	200	200	212.5					
L3	124	134.5	145	155.5	166	176.5	187	197.5					
L4	12	13	14	15	16	17	12	13					

L_n	10	11	12	13	14	15	16
L1	235.5	248	260.5	273	285.5	285.5	298
L2	225	237.5	250	262.5	275	275	287.5
L3	208	218.5	229	239.5	250	260.5	271
L4	14	15	16	17	18	12.5	13.5

External Pilot Manifold L Dimension n: Sta												
<u>L</u> n	n 2 3 4 5 6 7 8											
L1	160.5	173	185.5	198	210.5	210.5	223	235.5				
L2	150	162.5	175	187.5	200	200	212.5	225				
L3	134.5	145	155.5	166	176.5	187	197.5	208				
L4	13	14	15	16	17	12	13	14				
N 10 11 12 12 14 15 16												

	10	11	12	13	14	15	16
L1	248	260.5	273	285.5	285.5	298	310.5
L2	237.5	250	262.5	275	275	287.5	300
L3	218.5	229	239.5	250	260.5	271	281.5
L4	15	16	17	18	12.5	13.5	14.5

Air Cylinders

Rotary Actuators

Air Grippers

Air Preparation Equipment

Modular F.

Pressure Control Equipment


Fittings & Tubing

Flow Control Equipment


Type 60S6B Series 10-SZ3000 EX510 Gateway-type Serial Transmission System

How to Order Manifold

An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.



How to Order Valve Manifold Assembly



The asterisk denotes the symbol for assembly. Prefix it to the part

no. of the solenoid valve, etc. . Stations are counted from the D side as the 1st one Add the valve part number under the manifold part number. For complex arrangements, specify them on the manifold specification

SI unit part no.

D D side

В

Symbol	SI unit specifications	SI unit part no.
Nil	NPN output (+ COM)	EX510-S002B
N	PNP output (- COM)	EX510-S102B

2 to 10 stations

Both sides 2 to 16 stations

manifold specification sheet.


blocks can be mounted.

Please contact SMC if 4 or

Note) A total of up to 3 SUP/EXH


more will be mounted.

Special specifications For special specifications, indicate separately with the



Dimensions: 10-SZ3000 for EX510 Gateway-type Serial Transmission System

10-SS5Z3-60S6B D- Stations U-



Note) For manifold dimensions with elbow fitting, refer to page 392.


Intern	al Pilo	ot Mar	nifold	L Dir	nensi	n: Stations			
/_	2	3	4	5	6	7	8	9	10
L1	160.5	173	185.5	185.5	198	210.5	223	235.5	248
L2	150	162.5	175	175	187.5	200	212.5	225	237.5
L3	128.6	139.1	149.6	160.1	170.6	181.1	191.6	202.1	212.6
L4	16	17	18	12.5	13.5	14.5	15.5	16.5	17.5

Exter	External Pilot Manifold L Dimension n: Stations												
L n	2	3	4	5	6	7	8	9	10				
L1	173	185.5	185.5	198	210.5	223	235.5	248	260.5				
L2	162.5	175	175	187.5	200	212.5	225	237.5	250				
L3	139.1	149.6	160.1	170.6	181.1	191.6	202.1	212.6	223.1				
L4	17	18	12.5	13.5	14.5	15.5	16.5	17.5	18.5				
405								Ø:	SMC				

Directional Control Valves

Dimensions: 10-SZ3000 for EX510 Gateway-type Serial Transmission System

10-SS5Z3-60S6B D- Stations B-



Note) For manifold dimensions with elbow fitting, refer to page 392.

Intern	al Pilo	ot Mar	nifold	L Dimension n: Station											: Stations
L n	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	173	185.5	198	210.5	223	223	235.5	248	260.5	273	285.5	298	298	310.5	323
L2	162.5	175	187.5	200	212.5	212.5	225	237.5	250	262.5	275	287.5	287.5	300	312.5
L3	144.6	155.1	165.6	176.1	186.6	197.1	207.6	218.1	228.6	239.1	249.6	260.1	270.6	281.1	291.6
L4	14	15	16	17	18	13	14	15	16	17	18	19	13.5	14.5	15.5


Exteri	External Pilot Manifold L Dimension n: Stations														Stations
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	185.5	198	210.5	223	223	235.5	248	260.5	273	285.5	298	298	310.5	323	335.5
L2	175	187.5	200	212.5	212.5	225	237.5	250	262.5	275	287.5	287.5	300	312.5	325
L3	155.1	165.6	176.1	186.6	197.1	207.6	218.1	228.6	239.1	249.6	260.1	270.6	281.1	291.6	302.1
L4	15	16	17	18	13	14	15	16	17	18	19	13.5	14.5	15.5	16.5

Type 60GD Series 10-SZ3000 System Plug-in Type






An order cannot be placed with only the manifold part no. Be sure to order solenoid valves for mounting at the same time while referring to the ordering example.




How to Order Valve



Air

How to Order Valve Manifold Assembly

Ordering example (10-SZ3000, positive common with power supply terminal)



10-SS5Z3-60GD2-05U····1 set (Manifold part no.)

- * 10-SZ3160-5LOZ-C6......2 sets (Single solenoid part no.)

 * 10-SZ3260-5LOZ-C6......3 sets (Double solenoid part no.)
- * 10-523260-5LOZ-C6-----3 sets (Double solenoid part
 - The asterisk denotes the symbol for assembly.


 Prefix it to the part no. of the solenoid valve, etc.
- Stations are counted from the D side as the 1st one.
 Add the valve part number under the manifold part number.
- For complex arrangements, specify them on the manifold specification sheet.

Manifold Specifications

Model		Flat ribbon cable type 60G
Manifold		Plug-in type
P(SUP)/R(EXH)		Common SUP, EXH
Valve stations Note 1)		2 to 16 stations
Applicable connector		Flat ribbon cable connector Socket: 20 pin MIL type with strain relief Conforming to MIL-C-83503
A, B port	Location	Valve
Porting specifications	Direction	Lateral
Port size	P, R port	C8
Port Size	A/B port	C4, C6, M5
Weight W(g) Note 2) n1: Stations n2: Number of SUP/EX m: Weight of DIN rail	(H blocks)	W = 3.2n ₁ + 53n ₂ + m + 126.5

- Note 1) This manifold is applicable to up to 16 solenoid valves. When many valves are operated simultaneously, use B type (SUP/EXH both sides), applying pressure to the P ports on both sides and exhaust from the R ports on both sides.
- Note 2) The weight W is the value for the manifold only. To obtain the weight with solenoid valves attached, add the weight of the solenoid valve stations to that of the manifold. For DIN rail weight, refer to page 384.


Manifold Electrical Wiring



- This circuit has double wiring specification with up to 8 stations. Since the usable number of solenoids differs depending on the manifold type, refer to the left table. For single solenoids, connect to SOL.A. Furthermore, when wiring is specified on the manifold specification sheet, connections are made without skipping any connectors, and signals A for single and A, B for double are in order 20 18 16 14, etc.
- Stations are counted from the D side (Connector side) as the 1st one.
- Since terminal numbers are not indicated on the flat cable, use the triangle mark as a reference for wiring.


SIVIC


10-SS5Z3-60GD₂ - Stations U-□




Inter	nal Pil	ot Ma	nifold	L Din	nensic	n		n: Stations			
<u></u>	2	3	4	5	6	7	8	9	10		
L1	110.5	123	135.5	148	148	160.5	173	185.5	198		
L2	100	112.5	125	137.5	137.5	150	162.5	175	187.5		
L3	81	91.5	102	112.5	123	133.5	144	154.5	165		
L4	15	16	17	18	12.5	13.5	14.5	15.5	16.5		

Exte	External Pilot Manifold L Dimension										
$\overline{\sim}$	ે 2	3	4	5	6	7	8	9	10		
L1	123	135.5	148	148	160.5	173	185.5	198	210.5		
L2	112.5	125	137.5	137.5	150	162.5	175	187.5	200		
L3	91.5	102	112.5	123	133.5	144	154.5	165	175.5		
L4	16	17	18	12.5	13.5	14.5	15.5	16.5	17.5		







Internal Pilot Manifold L Dimension n: Stations											Stations				
<u> </u>	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	123	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	248	248	260.5	273
L2	112.5	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	237.5	237.5	250	262.5
L3	97	107.5	118	128.5	139	149.5	160	170.5	181	191.5	202	212.5	223	233.5	244
L4	13	14	15	16	17	12	13	14	15	16	17	18	12.5	13.5	14.5

Exteri	External Pilot Manifold L Dimension n: Stations												Stations		
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
L1	135.5	148	160.5	173	173	185.5	198	210.5	223	235.5	248	248	260.5	273	285.5
L2	125	137.5	150	162.5	162.5	175	187.5	200	212.5	225	237.5	237.5	250	262.5	275
L3	107.5	118	128.5	139	149.5	160	170.5	181	191.5	202	212.5	223	233.5	244	254.5
L4	14	15	16	17	12	13	14	15	16	17	18	12.5	13.5	14.5	15.5

Series 10-SZ3000 Made to Order


Please contact SMC for detailed specifications, delivery and pricing.



Fluororubber is used for rubber parts of the main valve to allow use in applications such as the following.

- When using a lubricant other than the recommended turbine oil, and there is a possibility of malfunction due to swelling of the spool valve seals.
- 2. When ozone enters or is generated in the air supply.


Model no.




Note) Because in series -X90 fluororubber is used for only main valve, the rubber parts of the application/usage in conditions requiring heat resistance should be avoided.

Plug-in Manifold Connector and Serial Unit Mounted on U Side

Products are also available with the plug-in manifold connector mounting position and the serial unit mounting position on the reverse side (U side). For details about part numbers and wiring specifications, etc., please contact SMC.






Rotary


↑Specific Product Precautions 1

Be sure to read this before handling.

Manual Override Operation


Handle carefully, as connected equipment can be actuated through manual override operation.





■Push-turn locking slotted type

While pressing the lock down, turn it in the direction of the arrow. If it dose not turn, it can be operated the same way as the non-locking type




▲ Caution

When locking the manual override on the push-turn locking slotted type, be sure to push the lock down before turning it.

Turning without first pushing it down can cause damage to the manual override and other trouble such as air leakage, etc.

Valves with Switches


When turning OFF with the switch, be sure to move the switch to the locked position. Connected equipment may be actuated if current flow occurs with the switch at an improper position.



operating state. Normal Switching of valve is based on an electric signal from the connector

The valve coil is kept in a de-energized state even when there is an electric signal from the connector.

Electric circuit diagram (With positive common and light/surge voltage suppressor)




How to Use Plug Connector

When attaching and detaching a connector, first shut off the electric power and the air supply

Also, crimp the lead wires and sockets securely.

1. Attaching and detaching connectors

- To attach a connector, hold the lever and connector unit between your fingers and insert straight onto the pins of the solenoid valve so that the lever's pawl is pushed into the groove and locks.
- To detach a connector, remove the pawl from the groove by pushing the lever downward with your thumb, and pull the connector straight out.



2. Crimping connection of lead wire and socket

Strip 3.2 to 3.7 mm at the end of lead wires, insert the end of the core wires. evenly into the sockets, and then crimp it with a crimping tool. When this is done, take care that the coverings of the lead wires do not enter the core wire crimping area. (Crimping tool: Model no. DXT170-75-1)

ng retainer




3. Attaching and detaching lead wire with socket Attaching

Insert the sockets into the square holes of the connector (+) and - indication), and continue to push the sockets all the way in until they lock by hooking into the seats in the connector. (When they are pushed in, the hooks open and they are locked automatically.) Then confirm that they are locked by pulling lightly on the lead wires.

Detaching

To detach a socket from a connector, pull out the lead wire while pressing the socket's hook with a thin tipped stick (approx. 1 mm). If the socket is to be used again, first spread the hook outward.



■Plug connector lead wire length

Standard length is 300 mm, but the following lengths are also available.

How to Order M Type Connector Assembly

Positive common specifications For single solenoid: SX100-40-4S-For double solenoid

For 3 position type: For 4 position type

Negative common specifications

For single solenoid: SX100-41-4S-For double solenoid For 3 position type: For 4 position type SX100-41-4D-

How to Order Specify the part numbers of the

solenoid valve without connector and the connector assembly with protective cover separately.

<Example> Lead wire length 2000 mm 10-SZ3160-5MO-M5

Nil

6

10 1000 mm

15 1500 mm

20 2000 mm

25 2500 mm

30 3000 mm

50 5000 mm

Lead wire length

300 mm

600 mm

SX100-40-4S-20

Switches/ e Sensors Pressure



▲Specific Product Precautions 2

Be sure to read this before handling.

Common Connector Assembly for Manifold

By using a common connector assembly for the solenoid valves on a manifold, the common wiring for each solenoid valve is reduced to one line, making it possible to achieve labor savings on wiring work

mon connector assembly part numbers

Positive common specifications For single solenoid SX100-42-4S



3 position, 4 position types SX100-42-4D



single solenoid SX100-40-4S



With common lead wire for double solenoid, 3 position, 4 position types SX100-40-4D



(Lead wire length 300 mm)

Negative common specifications For single solenoid SX100-43-4S



For double solenoid, 3 position, 4 position types SX100-43-4D



With common lead wire for single solenoid SX100-41-4S



With common lead wire for double solenoid, 3 position, 4 position types SX100-41-4D



(Lead wire length 300 mm)


How to Order

Include the common connector assembly part number together with the manifold and solenoid valve part numbers. If the arrangement becomes complicated, then indicate on the manifold specification sheet

Note 1) Take note that applications with unused connectors or with blanking plates between stations are not possible


Note 2) For the solenoid valve, specify "without connector" for the plug connector type. The grommet type cannot be used

Note 3) In places where signals will be sent to the common wiring, use a connector assembly with a common lead wire. (This is limited to the first station or the last station of a manifold.)



Common Connector Assembly Wiring

When ordering common connector assemblies only, wiring should be performed as outlined in the drawing below. For details on attachment of sockets, refer to the How to Use Plug Connector on page 412.



⚠ Caution

One-touch Fittings

The pitch determined for each of the 10-SZ series piping ports (P, A, B, etc.) is based on the assumption that the 10-KQ2 series One-touch fittings will be used. For this reason, other pipe fittings may interfere with each other depending on their type and size. Dimensions should be confirmed in a fitting catalog before they

⚠ Caution

Exhaust Throttle

With the 10-SZ series, the pilot valve and main valve share a common exhaust inside the valve. Therefore, do not block the exhaust port when installing the

10-SZ3000 Series Used as a 3 Port Valve

When using a 5 port valve as a 3 port valve

The 10-SZ3000 series valves can be used as normally closed (N.C.) or normally open (N.O.) 3 port valves by closing one of the cylinder ports (A or B) with a plug. However, they should be used with the exhaust ports kept open. They are convenient at times when a double solenoid type 3 port valve is required


Plug	position	B port	A port				
Actuat	ion type	N.C.	N.O.				
Number of solenoids	Single	(A)4 2(B) (EA)5 1 3(EB)	(A)4 2(B) (EA)5 1 3(EB)				
Number of	Double	(A)4 2(B) (EA)5 1 3(EB)	(A)4 2(B) (EA)5 1 3(EB)				


△Specific Product Precautions 3

Be sure to read this before handling.

Light/Surge Voltage Suppressor

Positive common specifications Single solenoid type







Positive common specifications Double solenoid, 3 position,

4 position types

Light/surge voltage suppressor







Surge voltage suppresso [SOL.B] White (-)



Negative common specifications Single solenoid type






Negative common specifications

Double solenoid, 3 position, 4 position types

Light/surge voltage suppressor



Surge voltage suppressor



Note) Connect so that polarity is matched to the connector's (+), (-) and A, B and COM indicators. In case of voltage specifications other than 12 or 24 VDC, take care to avoid mistaking polarity, as there is no diode to prevent reverse current. In the event that lead wires are connected in advance, they will

be as shown below. Positive common specifications

(-): Black COM (+): Red

(-): White (No lead wire in case of single solenoid)

Negative common specifications

(+): Black


COM (-): Yellow

(+): White (No lead wire in case of single solenoid)

⚠ Caution

Light Indication

When equipped with indicator light and surge voltage suppressor, the light window turns orange when solenoid A is energized, and it turns green when solenoid B is energized.




⚠ Caution

Changing the Connector Entry Direction

To change the connector entry direction, set the switch on the top of the connector block to the FREE position, and turn the connector. Make sure to set the switch back to the LOCK position before connecting the connector. (When the switch is difficult to slide, move the connector a little so that it will slide easier.)

If an excessive force is applied on the connector in the LOCK position, the connector block may be damaged. Also, using in such a way that the connector floats in the FREE position, it may cause the lead wire, etc. to break. Thus, refrain from using in these ways.



▲Specific Product Precautions 4

Be sure to read this before handling.

One-touch Fittings

Tubing attachment/detachment for One-touch fittings

1) Attaching of tubing

- (1) Take a tubing with no flaws on its periphery and cut it off at a right angle. When cutting the tubing, use tube cutters TK-1, 2 or 3. Do not use pinchers, nippers or scissors, etc. If cutting is done with tools other than tube cutter, the tubing may be cut diagonally or become flattened, making a secure installation impossible, and cause problems such as the tubing coming out after installation or air leakage.
 - Allow some extra length in the tubing.
- (2) Grasp the tubing and push it in slowly, inserting it securely all the way into the fitting.
- (3) After inserting the tubing, pull on it lightly to confirm that it will not come out. If it is not installed securely all the way into the fitting, this can cause problems such as air leakage or the tubing coming out.

2) Detaching of tubing

- Push in the release button sufficiently, pushing its collar equally around the circumference.
- (2) Pull out the tubing while holding down the release button so that it does not come out. If the release button is not pressed down sufficiently, there will be increased bite on the tubing and it will become more difficult to pull it out.
- (3) When the removed tubing is to be used again, cut off the portion which had been secured before reusing it. If the same portion of the tubing is reused, this can cause trouble such as air leakage or difficulty in removing the tubing.

⚠ Caution

Other Tubing Brands

- When using tubing other than SMC brand tubing, confirm that the following specifications are satisfied with respect to the outside diameter tolerance of the tubing.
 - 1) Nylon tubing within ±0.1 mm
 - 2) Soft nylon tubing within ±0.1 mm
 - 3) Polyurethane tubing within +0.15 mm, within -0.2 mm

Do not use tubing which do not meet these outside diameter tolerances. It may not be possible to connect them, or they may cause other trouble, such as air leakage or the tubing coming out after connection.

Built-in Back Pressure Check Valve

- 1. Valves with built-in back pressure check valve are to protect the back pressure inside a valve. For this reason, use caution that the valves with external pilot specifications cannot be pressurized from exhaust port [3(R)]. As compared with the types which do not integrate the back pressure check valve, C value of the flow rate characteristics goes down. For details, please contact SMC.
- 2. Do not switch valves when A or B port is open to the atmosphere, or while the actuators and air operated equipment are in operation. The back pressure prevention seal may be peeled off, which may cause air leakage or malfunctions. Use caution especially when performing a trial operation or maintenance work.