
Controller for Electro-Pneumatic Regulator

IC Series

Converts digital input signal into analog output signal



To bit parallel input signal (maximum)

Pressure can be set with 2¹⁰ = 1024 steps.

Digital input data 1023

Digital signal

Controller

0-10 VDC


4-20 mA DC ITV se

4 point pressure switch function Switch output is enabled by setting the upper and lower limits of pressure.

1bit 2bit

10 bit

IC Series



Power voltage and output signals

Output power voltage and output signal to the electro-pneumatic

	re	gulator	can be set v	with keys on	the front p	oanel.		
1		Power supply voltage	Output signal		Controller	Power supply	Electro-pneumatic regulator	No need of power supply for ITV
	1	12 VDC	4 to 20 mA DC		OSIC CONTROLLER OUT PRESSURE	voltage	regulator	Power supply for
	2	12 VDC	0 to 10 VDC	Power supply for controller	88888			electro-pneumatic
	3	24 VDC	4 to 20 mA DC		A STEREO			regulator
	4	24 VDC	0 to 10 VDC		UP RIN RED STO 0000	Output signal	ITV Series	
Ü					IC Series			

This product is mainly used in combination with ITV0000 series without a display function.

ARJ

AR425

to 935

ARX

AMR

ARM

ARP

IR□-A IR IRV

VEX SRH

SRP

SRF

ITV IC

ITVH

ITVX

PVQ


VY1

VBA VBAT

AP100

Controller for Electro-Pneumatic Regulator *IC Series*

How to Order




Option

When only optional parts are required, order using the part numbers listed below.

Description	Part no.	Note
Panel mount adapter set	P398050-1	Gasket, Screw 2 pcs.
Display protective cover	P2992136	-





Specifications

	Model	IC1□	IC3□	IC5□	IC9□	l
Pressure rang	ge	0.1 MPa	0.5 MPa	0.9 MPa	-0.1 MPa	l
Proof pressure		500 kPa 1.5 MPa 500 kPa				
Fluid		Air/Non-corrosive gas				AR
Dimensions		48 x 48 x 100.5				An
Power supply	1	12 to 24 VDC (15 W or more), Ripple (p-p) 1% or less				AR42
		①No	o. of inputs: Up to 10 bit inputs.	ut from sequencer (paralle	() Note 5)	to 93
		Input method: No-voltage contact or NPN open collector input				AR
Input		Minimum pulse width: 50 msec				An.
		②Input method: 4 point input with keys				AMR
		(In	terval time can be set by pr	ogramming.)		AIVI
Power supply	/ output	12 V	/DC (Max. 300 mA) with ac	curacy of 12 to 14.4 VDC	Note 2)	ARI
i ower suppry	Catput	24	VDC (Max. 300 mA) with a	accuracy of 22.0 to 26.8 V	DC	AIII
Command ou	itnut	①0 to 10 Vc (0	Output resistance: 6.5 kΩ or	more with accuracy of 0.5	5%F.S. or less)	AR
Command ou	при	②4 to 20 mA [OC (Output resistance: 800	Ω or less with accuracy of	0.5%F.S. or less)	AIII
			Output: 4 points			l IR□-
			Output type: NPN, PNP op	•		
Switch output	+		Withstand voltage: Max. 30	V		IR
omion outpu	•	Current: Max. 100 mA				
		Internal voltage drop: 1 V or less				IR۱
		Switching between N.O. and N.C. modes is possible.				
Switch response		5 to 640 ms				VE
		Power indication: 3 1/2-digit LED indicator (red)				
Display		Output power supply voltage and current signal indication: 1-digit LED indicator (red)			D indicator (red)	SR
		LED lights for RUN, CH, SW (red and green)				
Display accur	· ·	±0.5%F.S. ±1dig (at 25°C)				SR
Display samp	_	Approx. 4 times/s				
•	characteristics	±0.12%F.S./°C				SR
Error indication			Displayed on press			l
	Operating temperature range	0 to 50°C				IT\
	Storage temperature range	−20 to 60°C				
Resistance	Operating humidity range	0 to 85%R.H.				
	Vibration resistance	10 to	55 Hz 1.5 mm amplitude		. each	IC
	Impact resistance	100 m/s² (approx. 10 G) X, Y, Z direction				— ∣ITVH
0	Water resistance	Only display unit with cover is equivalent to IP65. It is equivalent IP40 without cover.		without cover.	ı	
Sensor type		Built-in sensor type, External sensor type Note 3)				ITV
Set value retention		10 years when deenergized (EEPROM)				
Port size		M5 female (built-in sensor type)				PV
		Enclosure: POM				
Material		Display: PC				
wateriai		Gasket: NBR				VP.4
		Panel mount adapter: POM Display protective cover: PC				VBA VBA
						-
Weight		Approx. 330 g (Built-in sensor type)			AP10	
		Approx. 345 g (External sensor type)				, —

Note 1) The display accuracy is the accuracy of the LED indication when the sensor port of the built-in sensor type is pressurized.

Note 5) For the ITV1000 to 3000 series, a 10-bit input (parallel) through a sequencer is available for -X93, -X157 (CE-compliant).

Note 2) The external sensor type has the same output power supply voltage specifications.

Note 3) The sensor for the external sensor type is not attached and must be ordered separately.

Any pressure sensor that transmits analog output signals can be connected.

Recommended sensor: PSE530 series (For more information, please refer to Best Pneumatics No. 8.)


Note 4) Button operation is required when turning the power on again. However, the made-to-order specification (-X2) automatically returns to the pre-shutdown state when power is switched on again.

IC Series

Functions

■ 4 point preset output

- · Four points (CH1 to CH4) of pressure and switch output ranges can be set with the front panel keys.
- · Up to 20 steps of programming is possible.
- · Interval time (1 to 999 sec) can be set by programming.
- · The set pressures can be arranged in a random order.




■ 10 bit parallel input

- · Up to 10 bits of parallel input is possible from PLC.
- · Pressure can be set with 210 = 1024 steps.



■ Pressure switch function (4 point)

Switch output is enabled by setting the upper and lower limits.



Power supply voltage and output signal switch function

- Output power supply voltage and output signal to the electro-pneumatic regulator can be selected with the front panel keys.
- \cdot No need of power supply for the electro-pneumatic regulator.
- · Stable power supply is possible.

	Power supply voltage	Output signal
1	12 VDC	4 to 20 mA DC
2	12 VDC	0 to 10 VDC
3	24 VDC	4 to 20 mA DC
4	24 VDC	0 to 10 VDC

950

Set pressure correction function (only for 4 point preset input)

Either automatic or manual adjustment is possible in pressure adjustment mode.

<Automatic adjustment mode>

The controller automatically calculates the deviation and converts the correction value into the output signal. The deviation converges within the range of $\pm 0.5\% F.S.$

Note) If the set pressure is 250 kPa and the output pressure on the pressure sensor is 245 kPa, the deviation is 250-245=5 kPa. In order to correct the deviation, the controller increases the output signal until the pressure on the pressure sensor converges at 250 kPa.

<Manual adjustment mode>

The deviation is corrected manually (with keys).

■ Zero span correction function

Deviation of the zero span point of the sensor can be corrected.

Keypad lock function

To prevent erroneous operation, operation on the key can be disabled. Keys which cannot be locked:



■ Reset function

The data is reset to the initial condition at the time of shipment.

Anti-chattering function

Large bore cylinders and ejectors consume a large volume of air in operation and occasionally experience temporary drops in supply pressure. This function prevents detection of such momentary supply pressure drops. It regards them as abnormalities and changes the response time settings. Possible response time settings: 5 ms, 20 ms, 160 ms, 640 ms


<Principle>

The controller equalizes the pressures measured during the specified response time. It then compares the equalized pressure and the set pressure to output switch signals accordingly.

■ Error display

Error name		Error indication	Description		
	SW1	Er 1			
Overcurrent	SW2	ErZ	Excess current is running through		
error	SW3	E - 3	switch.		
	SW4	Ery			
Switch range e	error	Er5	Lower limit of switch output exceeds upper limit.		
Pressurization error			Pressure exceeding upper limit of set pressure is applied.		

Descriptions




No.	Description					
1	OUT display Displays output specification to electro-pneumatic regulator.					
2	RUN display Displays control status.					
3	CH channel (display) (for 4 point input) Of CH1 to CH4 for pressure selection, channel with output ON lights up.					
4	SW (switch) output display Displays output type and output status of SW1 to 4.					
(5)	UP button Used to change mode and set value.					
6	SET/RUN button Used to confirm mode and set value, or to change to control ON state.					
7	D-IN/READ button Used to select mode and turn on or off power supply to electro-pneumatic regulator.					
8	P-ON/STOP button Used to turn on or off main power supply, escape from mode, or change to stand-by state.					
9	DOWN button Used to change mode and set value.					
10	Pressure display Displays measured value, settings, and error code.					

IC -0 (Internal sensor type) IC -1 (External sensor type Breathing port (M3 x 0.5 x 9.5) Sensor pressure port (M5 x 0.8 x 7)

)	No.	Description	Note
	1	Power supply, 10 bit input cable	13 wire, O.D. 6.8 mm, 1 m length
	2	Cable for 4 point switch output	5 wire, O.D. 6 mm, 1 m length
	3	Pneumatic regulator connection cable	0 i 0 D 0 4 4 i 4
	4	Cable for external sensor	3 wire, O.D. 3.4 mm, 1 m length

Note 2) Since the electro-pneumatic regulator connection cable (3) and the cable for external sensor 4 are identical in shape, take precautions against erroneous connection.

Internal Circuit and Connection



For the setting procedure and detailed cable connection specifications, please refer to the operation manual.

ARJ AR425

to 935 ARX

AMR

ARM ARP IR□-A IR

IRV

VEX SRH

SRP

SRF

ITV

IC

ITVH

ITVX

PVQ

VY1

VBA


VBAT

AP100

Note 1) If the power supply for loads and main power supply are provided by a common source, the power supply (GND) can be used for SW-DC (GND).

Breathing port

(M3 x 0.5 x 9.5)




Note 1) Connection to the pressure sensor is required only when using the external sensor type.




IC Series

Dimensions



Option





IC Series Specific Product Precautions

Be sure to read this before handling the products. Refer to back page 50 for Safety Instructions.

■ Controller for Electro-pneumatic Regulator

Handling

Δ Warning

- Do not drop, bump, or apply excessive impacts (980 m/s²) while handling. Although the body of the sensor may not be damaged, the inside of the sensor could be damaged and lead to a malfunction.
- 2. The tensile strength of the cord is 20 N. Applying a greater pulling force on it can cause a malfunction. When handling, hold the body of the sensor do not dangle it from the cord.
- Do not exceed the tightening torque of 3.5 N·m when installing piping. Exceeding this value may cause malfunctioning of the sensor.
- 4. The minimum bending radius of the cable is 50 mm.
- 5. Do not use pressure sensors with corrosive and/or inflammable gases or liquids.

Operating Environment

Δ Warning

 This controller for electro-pneumatic regulator is not rated as explosion proof.

Never use it in an atmosphere of corrosive or explosive gas.

△Caution

 Only the display unit of the controller for electropneumatic pressure regulator has an enclosure equivalent to IP65 rating.

Connection


∆ Caution

- Incorrect wiring can damage the switch and cause a malfunction or erroneous switch output. Connections should be done while the power is turned off.
- Do not attempt to insert or pull the pressure sensor or its connector when the power is on. Switch output may malfunction.
- Wire separately from power lines and high voltage lines, avoiding wiring in the same conduit with these lines. Malfunctions may occur due to noise from these other lines.
- If a commercial switching regulator is used, make sure that the F.G. terminal is grounded.

Mounting

⚠ Caution

1. Mounting with panel mount adapter



Tighten screws by 1/4 to 1/2 turn after the heads are flush with the panel.

ARJ

AR425 to 935

AMR

ARM

IR□-A

IR IRV

VEX

SRH

SRP

SRF

IC

ITVH ITVX

PVQ VY1

> VBA VBAT

